



MANUFACTURER'S TEST CERTIFICATE

Date: 07/02/18

Description: T5 ECG 1X28W Ballast-----LEDVANCE with pulse Brand

Lot Size : 1000 N

Physical Dimensions

Sample Size: 10 N

Parameter	Standard	Actual
Length	220±2	within specification
Width	30±2	within specification
Height	25±2	within specification

Safety Requirements

Sample Size: 10N


	Standard	Actual
Electric Strength	1.5kV	within specification

Electrical parameters

Sample Size: 10 N

Parameter	Standard	Actual
Input Current	126~154mA	within specification
Input Power	27.45 ~ 33.55W	within specification
Power Factor	≥ 0.9	within specification

The full lot comply with all the standard parameters.


(Vishal Bhardwaj)
Manager (QA)